



SECTION E-E



NOTES

- I. For Details of concrete pipe inlets, see New Standard Plan NSP D75B.
- For details of ladder and steps and when ladder or steps are required, see Standard Plan NSP D75C.
- 3. Inlet pipes shall not protrude into basin.
- Except for inlets used for junction boxes, basin floors shall have minimum slope of 1:4 from all directions toward outlet pipe, and a wood trowel finish.
- 5. See Standard Plans D77A and D77B for Grate and Frame Details and mass of Miscellaneous Iron and Steel.
- 6. Designation of Type OMPI pipe inlets on plans indicates trash racks are to be furnished and installed on all side openings. See New Standard Plan NSP D75C for trash rack
- More than one side opening may be required. Location and number as ordered by the Engineer.
- 8. Chain to be provided when specified. 9. Caulk seal with pliable mixture of sand, portland cement, and
- emulsified asphalt (Mixture of I part portland cement, 3-5 parts sand, and 1/2 parts SSI emulsified asphalt.)
- 10. Place pipe so bars of grate will be parallel with main

STATE OF CALIFORNIA DEPARTMENT OF TRANSPORTATION

PIPE INLETS

NO SCALE

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN

D75A